

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

## TEST REPORT

**Client :** Golden Field Corporation Pty Ltd  
9-11 Hillwin Street  
Reservoir VIC 3073

**Test Number :** 18-002823  
**Issue Date :** 29/05/2018  
**Print Date :** 8/06/2018

**Sample Description** Clients Ref : "Noble Oak Flooring"  
Engineered timber plywood floor panel with oak facing  
End Use : Floating floor with tongue & groove click system  
Nominal Composition : European Oak Timber  
Nominal Mass per Unit Area/Density : Approx: 7.5kg/m2  
Nominal Thickness : 14mm

**AS 4586-2013**  
**Appendix A**

### Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Test 28/05/2018  
Test Temperature (20±5degC) 22 °C  
Sample Preparation Washed with pH neutral detergent and then dried.  
Test Direction Length  
Fixed/Unfixed Unfixed  
Slider No 96 Batch No 72  
Length 1 2 3 4 5 SRV  
British Pendulum Number 46 43 46 43 41 44  
Classification P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 16/10/2017  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

131702

27935

Page 1 of 1

© Australian Wool testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing  
- Mechanical Testing  
- Performance & Approvals Testing

: Accreditation No. 983  
: Accreditation No. 985  
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)  
MANAGING DIRECTOR