## **AWTA Product Testing**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: Golden Field Corporation Pty Ltd

> 9-11 Hillwin Street Reservoir VIC 3073

18-002824 Test Number : **Issue Date** 

31/05/2018

**Print Date** 8/06/2018

"Green Earth Waterproof Flooring **Sample Description** Clients Ref:

> Vinyl tile with water proof backing Natural wood effect Colour:

End Use: Waterproof floating flooring with 5G click system Calcium carbonate and PVC Nominal Composition: Nominal Mass per Unit Area/Density: Approx: 9.4kg/m2

Nominal Thickness: 6.5mm

AS 4586-2013 Appendix A

## Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Test 29/05/2018 Test Temperature (20±5degC) 22 °C

Sample Preparation Washed with pH neutral detergent and then dried.

**Test Direction** Length

Fixed/Unfixed Unfixed

Slider No 96 Batch No 72

Lenath 1 2 3 5 SRV British Pendulum 50 51 50 51 51 51

Number

Classification P4

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 16/10/2017 Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

131708 27936 Page 1 of 1

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



the Managing Director of AWTA Ltd.

Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing


Mechanical Testing

Performance & Approvals Testing

: Accreditation No Accreditation No

· Accreditation No. 1356

983





A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY